

测试报告

报告号: **AJHL1601000974FB_CN** 日期: **2016年2月14日** 第 **2** 页 共 **4** 页

I. 测试方法

本测试按照 EN 13501-1:2007+A1:2009 建筑制品和构件的火灾分级 第 1 部分: 用对火反应试验数据的分级进行, 测试方法如下:

- EN ISO 1182:2010 建筑制品对火反应试验—不燃性试验
- EN ISO 1716:2010 建筑材料及制品的燃烧性能-燃烧热值的测定

II. 样品信息

颜色	白色
----	----

III. 测试结果

测试方法	参数	样品数量	测试结果
EN ISO 1182	$\Delta T/K$	5	4
	$\Delta m/\%$		14.76
	t_f/s		0
EN ISO 1716	PCS/ MJ/kg ^a	3	0
	PCS/ MJ/kg ^b		不适合
	PCS/ MJ/m ² ^d		不适合
	PCS/ MJ/kg ^e		0

注释:

ΔT — 温升 [K]; Δm — 质量损失 [%]; t_f — 持续燃烧时间 [s]
 PCS — 总热值 [MJ/kg 或者 MJ/m²]

IV. 分级

本分级根据 EN 13501-1:2007+A1:2009 相关条款。

结论: 所提供样品, 软瓷, 分级如下,

燃烧性能等级: A1

注: 分级参数表见附录A。

备注: 在特定的试验条件下, 试验结果与试样的性能有关; 试验结果不能作为评估制品在实际使用条件下潜在火灾危险性的唯一依据

声明:

本测试报告不能作为制品的型式检验和认证。

实验室未曾参与产品的取样, 所测样品为厂家选送。

接下页...



This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Documents.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only.

AJHG 209007

SGS-通标标准技术服务有限公司
 Anji Branch 安吉县阳光工业园二区阳光大道301号

No. 301, Sunlight Road, 2 Block, Sunlight Industry Zone, Anji County, Zhejiang Province, China 313300 t (86-572) 5018825 f (86-572) 5018829 www.sgsgroup.com.cn
 中国·浙江·安吉县阳光工业园二区阳光大道301号 邮编: 313300 t (86-572) 5018825 f (86-572) 5018829 e sgs.china@sgs.com

Member of the SGS Group (SGS SA)